

EU Declaration of Conformity

Texecom



0832

Document Reference : DEC-K00193
Notified Body : BRE Global
0832-CPD-0762

Bradwood Court, St. Crispins Way
Haslingden, Lancashire, BB4 4PW
United Kingdom

Object of the declaration: Fire Bell

Part No.	Product Type	Description
TAA-0011	AB360	FIRE BELL INDOOR 6 Inch - UTC-EDWARDS
TAA-0012	AB360-06	FIRE BELL INDOOR 6 Inch - GE SWEDEN

Hereby, Texecom declares that this equipment is in compliance with the essential requirements and other relevant provisions of the Directives.

305/2011/EU	Construction Products Regulation
2014/30/EU	EMC Directive
2011/65/EU	ROHS Directive

This is demonstrated by conformity against the following harmonised standards

Standard	Edition/ Date of Issue	Title of Standard
EN 54-3	2001+A1:2002+A2:2006	Fire detection & fire alarm Systems-Part 3: Fire alarm devices-Sounders
EN 61000-6-3	2007/A1:2011/AC:2012	Electromagnetic compatibility (EMC) — Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments
EN 50130-4	2011	Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

This declaration is issued under the sole responsibility of the manufacturer.

Hugh Devereux
Head of Approval & Compliance



CERTIFICATE NUMBER: FM35285