



# USQT.S36565 - Extinguishing System Attachments

## Extinguishing System Attachments

**BEST FIRE PROTECTION SYSTEMS**

210 N Central Ave. #110  
 Glendale, CA 91203 United States

S36565

**SPRINKLER SYSTEM ALARM INITIATING DEVICES**

**Wet Pipe, Paddle Type**

Model	Size In.	Pipe Schedule	Max System Pressure psig
BFW	2.00	10 through 40	365
	2.5	10 through 40	365
	3.0	10 through 40	365
	4.0	10 through 40	365
	5.0	10 through 40	365
	6.0	10 through 40	365
	8.0	10 through 40	365

Last Updated on 2022-03-23

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"